

CERTIFICATE NO: 2635

TOWNSHIP: ROCK CREEK

SECTION: 33

**BARTHOLOMEW COUNTY HEALTH DEPARTMENT
440 THIRD STREET - SUITE 303
COLUMBUS, IN 47201-6798**

PHONE: (812) 379-1550

FAX: (812) 379-1040

**PRELIMINARY SEWAGE CERTIFICATE
(NOT A CONSTRUCTION PERMIT)**

FRONTING ON: NORTH SIDE OF COUNTY ROAD: 200 S. APPROXIMATELY: 1

FEET/MILES: WEST OF COUNTY ROAD: 900 E. (NEAREST CROSS ROADS)

ACRES: 1.63 DIMENSIONS: _____

SUBDIVISION: DEER RUN ESTATES, SITE ONE Hawks Landing LOT NO: 1

OWNER'S NAME: TOM FRANCISCO

MAILING ADDRESS: 15961 E. 200 S., COLUMBUS, IN 47203


SURVEYOR: E.R. GRAY & ASSOCIATES, INC.

SOIL SCIENTIST: AL DONALDSON SOIL ANALYSIS DATE: 12/11/2006


REQUIREMENTS

1. Install a septic tank, equipped with a gas tight riser, sized according to the number of bedrooms in the home.
2. Install 500 square feet of subsurface absorption field per bedroom in trenches not to exceed 16 inches in depth. Apply a minimum of 12 inches of soil over the aggregate, graded in a manner that promotes surface water runoff.
3. Install a perimeter drain along the upslope and side slopes of the system area at 48 inches in depth, located no closer than 10 feet to any part of the system area.
4. System area must be located no closer than 50 feet to any private water supply.
5. System area must be laid out and approved by this department prior to construction permit issuance.
6. The system area must be located 58 feet east of the western property line and 84 feet north of 200 S.
7. System area must be protected from excavation, grading, filling, compaction, or any other construction related activities that could render the site unsuitable if disturbed. This department recommends that a barrier be placed around the system area to protect it.

NOTE: Any home larger than three bedrooms will require the system to be pump assisted.

OWNER/AGENT SIGNATURE: 

DATE: 12/19/06

COMPLETED BY: 

DATE: 12-12-06

**BARTHOLOMEW COUNTY HEALTH DEPARTMENT
440 THIRD STREET - SUITE 303
COLUMBUS, IN 47201-6798**

PHONE: (812) 379-1550

FAX: (812) 379-1040

**PRELIMINARY SEWAGE CERTIFICATE
(NOT A CONSTRUCTION PERMIT)**

FRONTING ON: NORTH SIDE OF COUNTY ROAD: 200 S. APPROXIMATELY: 1

FEET/MILES: WEST OF COUNTY ROAD: BURNSVILLE (NEAREST CROSS ROADS)

ACRES: 1.63 DIMENSIONS: _____

SUBDIVISION: DEER RUN ESTATES, SITE TWO LOT NO: 1

OWNER'S NAME: TOM FRANCISCO

MAILING ADDRESS: 15961 E. 200 S., COLUMBUS, IN 47203

SURVEYOR: E.R. GRAY & ASSOCIATES, INC.

SOIL SCIENTIST: AL DONALDSON SOIL ANALYSIS DATE: 12/11/2006

REQUIREMENTS

1. Install a septic tank, equipped with a gas tight riser, sized according to the number of bedrooms in the home.
 2. Install 500 square feet of subsurface absorption field per bedroom in trenches not to exceed 15 inches in depth. Apply a minimum of 12 inches of soil over the aggregate, graded in a manner that promotes surface water runoff.
 3. Install a perimeter drain along the upslope and side slopes of the system area at 47 inches in depth, located no closer than 10 feet to any part of the system area.
 4. System area must be located no closer than 50 feet to any private water supply.
 5. System area must be laid out and approved by this department prior to construction permit issuance.
 6. The system area must be located 59 feet south of the northern property line and 56 feet east of western property line.
 7. System area must be protected from excavation, grading, filling, compaction, or any other construction related activities that could render the site unsuitable if disturbed. This department recommends that a barrier be placed around the system area to protect it.
- NOTE: Any home larger than three bedrooms will require the system to be pump assisted.

OWNER/AGENT SIGNATURE: _____
Robert

DATE: 12/18/06

COMPLETED BY: _____
Scott Murray

DATE: 12-12-06

CERTIFICATE NO: 2645

TOWNSHIP: ROCK CREEK

SECTION: 33

**BARTHOLOMEW COUNTY HEALTH DEPARTMENT
440 THIRD STREET - SUITE 303
COLUMBUS, IN 47201-6798**

PHONE: (812) 379-1550

FAX: (812) 379-1040

**PRELIMINARY SEWAGE CERTIFICATE
(NOT A CONSTRUCTION PERMIT)**

FRONTING ON: NORTH SIDE OF COUNTY ROAD: 200 S. APPROXIMATELY: 1

FEET/MILES: WEST OF COUNTY ROAD: 900 E. (NEAREST CROSS ROADS)

ACRES: 1.67 DIMENSIONS: _____

SUBDIVISION: DEER RUN ESTATES, SITE ONE Hawks Landing LOT NO: 6

OWNER'S NAME: TOM FRANCISCO

MAILING ADDRESS: 15961 E. 200 S., COLUMBUS, IN 47203

SURVEYOR: E.R. GRAY & ASSOCIATES, INC.

SOIL SCIENTIST: AL DONALDSON SOIL ANALYSIS DATE: 12/11/2006


REQUIREMENTS

1. Install a septic tank, equipped with a gas tight riser, sized according to the number of bedrooms in the home.
2. Install 500 square feet of subsurface absorption field per bedroom in trenches not to exceed 16 inches in depth. Apply a minimum of 12 inches of soil over the aggregate, graded in a manner that promotes surface water runoff.
3. Install a perimeter drain along the upslope and side slopes of the system area at 48 inches in depth, located no closer than 10 feet to any part of the system area.
4. System area must be located no closer than 50 feet to any private water supply.
5. System area must be laid out and approved by this department prior to construction permit issuance.
6. The system area must be located 45 feet south of the northern property line and 378 feet west of the eastern property line.
7. System area must be protected from excavation, grading, filling, compaction, or any other construction related activities that could render the site unsuitable if disturbed. This department recommends that a barrier be placed around the system area to protect it.

NOTE: Any home larger than three bedrooms will require the system to be pump assisted.

OWNER/AGENT SIGNATURE: 

DATE: 12/19/06

COMPLETED BY: 

DATE: 12-12-06

**BARTHOLOMEW COUNTY HEALTH DEPARTMENT
440 THIRD STREET - SUITE 303
COLUMBUS, IN 47201-6798**

PHONE: (812) 379-1550

FAX: (812) 379-1040

**PRELIMINARY SEWAGE CERTIFICATE
(NOT A CONSTRUCTION PERMIT)**

FRONTING ON: NORTH SIDE OF COUNTY ROAD: 200 S. APPROXIMATELY: 1

FEET/MILES: WEST OF COUNTY ROAD: 900 E. (NEAREST CROSS ROADS)

ACRES: 1.67 DIMENSIONS: _____

SUBDIVISION: DEER RUN ESTATES, SITE TWO Hawks Landing LOT NO: 6

OWNER'S NAME: TOM FRANCISCO

MAILING ADDRESS: 15961 E. 200 S., COLUMBUS, IN 47203

SURVEYOR: E.R. GRAY & ASSOCIATES, INC.

SOIL SCIENTIST: AL DONALDSON SOIL ANALYSIS DATE: 12/11/2006

REQUIREMENTS

1. Install a septic tank, equipped with a gas tight riser, sized according to the number of bedrooms in the home.
 2. Install 500 square feet of subsurface absorption field per bedroom in trenches not to exceed 16 inches in depth. Apply a minimum of 12 inches of soil over the aggregate, graded in a manner that promotes surface water runoff.
 3. Install a perimeter drain along the upslope and side slopes of the system area at 42 inches in depth, located no closer than 10 feet to any part of the system area.
 4. System area must be located no closer than 50 feet to any private water supply.
 5. System area must be laid out and approved by this department prior to construction permit issuance.
 6. The system area must be located 30 feet south of the northern property line and 257 feet west of the eastern property line.
 7. System area must be protected from excavation, grading, filling, compaction, or any other construction related activities that could render the site unsuitable if disturbed. This department recommends that a barrier be placed around the system area to protect it.
- NOTE: Any home larger than two bedrooms will require the system to be pump assisted.

OWNER/AGENT SIGNATURE: _____ *[Signature]*

DATE: 12/19/06

COMPLETED BY: _____ *[Signature]*

DATE: 12-12-06